



Timber Research and Development Institute Praha
Na Florenci 7-9, 111 71 Praha 1, Czech Republic

issues to the applicant:

KRONOSPAN CRO d.o.o.
Slavonska cesta 17
430 00 Bjelovar
Croatia

plant: KRONOSPAN CRO d.o.o., Slavonska cesta 17, 430 00 Bjelovar

CERTIFICATE

No.: 3318/26-1

for the product

ALUMINIUM FACED MDF, ACRYLIC FACED MDF


Prescriptions specifying the features of product: Commission Regulation (EU) 2023/1464 of 14 July 2023 amending Annex XVII to Regulation (EC) No 1907/2006 of the European Parliament and of the Council as regards formaldehyde and formaldehyde releasers (Regulation REACH) and IOS-MAT-0181, Version AA-2183046-6 from 2025-11-27.

This certificate confirms that the product mentioned above was tested according to published test requirements "*Commission Regulation (EU) 2023/1464 of 14 July 2023 amending Annex XVII to Regulation (EC) No 1907/2006 of the European Parliament and of the Council as regards formaldehyde and formaldehyde releasers (Regulation REACH)*", method EN 717-1, and formaldehyde release value fulfils the emission requirements according to the Article 29 of REACH and does not exceed the value 0,062 mg/m³. The product also fulfils the emission requirements according to Table 1 in IOS-MAT-0181, Version AA-2183046-6, Section 1.3.1. - EN 717-1 – 0,062 mg/m³.

This certificate is issued on the basis of Test report No. MVZ-A-2025-003903 from 17.12.2025.

This certificate replaces the certificate 3318/26 from 5.1.2026 and validity of this certificate is limited till 2028-01-05. This certificate will be deprived of validity if the conditions occurred due to changes do not correspond to those on which they were granted.

The applicant may enclose the document evidencing the conformity to the products, which are conformable to the certified one.



A. Jitka Beránková
Ing. Jitka Beránková, Ph.D.
Head of certification department

Prague, 2026-04-07

